

NPDES Permit No. IL0045209
Notice No. TRK:DSibls/6415C, sp
Date: MAR 06 1986

US EPA RECORDS CENTER REGION 5



483642

National Pollutant Discharge Elimination System (NPDES)
Permit Program

PUBLIC NOTICE/FACT SHEET

of

Proposed Modified NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois EPA
Division of Water Pollution Control
Permit Section
2200 Churchill Road
Springfield, Illinois 62706
217/782-0610

Name and Address of Discharger:

Williams Pipe Line Company
Box 3448
Tulsa, Oklahoma 74101

Name and Address of Facility:

Williams Pipe Line Company
10601 Franklin Park
Franklin Park, Illinois 60131
Cook County

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue an NPDES permit to discharge into the waters of the state and has prepared a draft permit for the above named discharger.

Length of Permit:

Approximately 5 Years

Name of Receiving Waters:

Silver Creek a tributary of the Des
Plaines River

Classification of Receiving Waters:

General Use

The following water quality and effluent standards and limitations were applied to the discharge:

Except as otherwise noted the effluent concentrations and load limitations (including toxics) were based on effluent and, if applicable, water quality limitations specified in Illinois Pollution Control Board (IPCB), Rules and Regulations, Subtitle C: Water Pollution.

The applicant is engaged in receiving, storing, and dispensing refined petroleum products (i.e., gasoline, aviation fuel, diesel fuel, and heating oil) (SIC 4613). Plant operation results in an average discharge of 0.01 FGD of stormwater runoff contaminated with refined petroleum product spillage from outfall 001.

Public Notice/Fact Sheet --- Page 2 --- NPDES Permit No. IL0045203

Flow will be monitored. The primary parameters to be monitored and limited are BOD₅, Total Suspended Solids, Oil (hexane soluble or equivalent), Fecal Coliform Bacteria, and pH.

Application is made for the existing discharge which is located in Cook County Illinois at latitude 41° 57' and longitude 87° 53'.

Monitoring frequencies and reporting requirements were established by using the authority set forth in 1PCB, Subtitle C: Water Pollution; Title 40, Section 122.11 and 122.62(i) of the federal regulations, and/or using the authority provided in Section 402(a)(1) of the Clean Water Act.

The effluent limitations and special conditions, if applicable, are appended as a part of the draft permit.

Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. The NPDES permit and notice number(s) must appear on each comment page. Any interested person may submit a written request for a public hearing on the draft permit, stating his or her name and address, the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday.

All comments on the draft permit and requests for hearing must be received by the IEPA not later than 30 days from the date of this publication. If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 30 days before any public hearing. For further information call the Public Notice Clerk at 217/782-0610.

Pursuant to the waiver provisions authorized by 40 CFR 123.6, this proposed permit is within the class, type, and size for which the Regional Administrator, Region V, has waived his right to review, object, or comment on this proposed permit action.

The Permittee intends on adding Outfall 002 to the existing NPDES Permit.